
For a Free Quote: Web: EnergyPal.com/solar Call: 1-800-990-3725 Email: contact@energypal.com

# **EnergyPal**


## Solar Panel Guide Specification Data Sheet

# Luxor Solar GmbH Eco Line M48/240-260W LX-255M

Also available on the web at EnergyPal.com/luxor-solar-gmbh-solar-panels/lx-255m









₩ **Cross-linking** 

Selection of components degree test



Performance surplus of 0 Wp to 6.49 Wp



sorting

Impp

Special packing to avoid micro cracks in the cells



German warrantor

The 48-cell solar module is compact and handy. Due to its flexibility, it can be optimally used especially for smaller roof areas. Eco in this case means especially economical: High-quality solar cell with highest efficiency at the best possible low light behaviour ensure the best energy output. And this at plus tolerances of 0Wp to 6.49Wp.

Further high-end components: An especially durable plugin connection guarantees the best power contact under all conditions, and the hollow-section frame made of anodised aluminium and compatible with every assembly system, is torsionally stiff and corrosion-free. Manufactured according to German standards each Luxor solar module is marked by a special level of durability and reliability.

# ECO LINE M48/240-260W

Monocrystalline module family

Module type LX - XXXM/156-48+ | XXX = Rated power Pmpp

### Electrical data at STC

Rated power Pmpp [Wp]	240.00	245.00	250.00	255.00	260.00	
Pmpp range to	246.49	251.49	256.49	261.49	266.49	
Rated current Impp [A]	9.32	9.41	9.51	9.60	9.70	
Rated voltage Vmpp [V]	25.78	26.07	26.38	26.65	26.87	
Short-circuit current lsc [A]	9.81	9.90	9.99	10.09	10.18	
Open-circuit voltage Uoc [V]	30.04	30.24	30.45	30.65	30.86	
Efficiency at STC	18.28%	18.68%	19.10%	19.49%	19.85%	
Efficiency at 200 W/m <sup>2</sup>	15.13%	15.41%	15.69%	15.97%	16.26%	_
Electrical data at NOCT						
Pmpp [Wp]	175.29	178.93	182.74	186.40	189.88	
Rated current Impp [A]	7.45	7.53	7.60	7.68	7.76	
Rated voltage Vmpp [V]	23.52	23.77	24.03	24.26	24.47	
Short-circuit current Isc [A]	7.84	7.92	7.99	8.07	8.14	
Open-circuit voltage Uoc [V]	27.41	27.57	27.73	27.90	28.10	

Specification as per STC (Standard test conditions): irradiance 1000 W/m2 | module temperature 25°C | AM = 1,5 NOCT (nominal operating cell temperature): irradiance 800 W/m2 | wind speed 1 m/sec | temperature 20°C | @45 +/- 2°C | AM = 1,5

### Limiting values

Max. system voltage [V]	1000 V
Max. return current [I]	15 A
Opterating Temperature	-40 to 85°C
Snow-load zone <sup>2</sup>	approval up to SLZ 3 (according to DIN 1055)
Max. pressure load (static) [Pa]	5400
Max. dynamic load [Pa]	2400

### Temperature coefficient

Temperature coefficient [V] | [I] | [P]

-0.30% /°C | 0.06% /°C | -0.40% /°C

### Specifications

Number of cells (matrix)	6 x 8, three strings in a row I 156 mm x 156 mm		
Module dimensions $(L \times W \times H)^2$   Weig	1324 mm x 992 mm x 35 mm   15.4 kg		
Front-side glass	3.2 mm hardened solar glass with low iron content		
Frame	stable, anodised aluminium frame in a hollow-section design		
Junction Box	At least IP65		
Cabel	4 mm <sup>2</sup> solar cable, cable length 1.0 m		
Diodes	3 Schottky Diodes 15A/45V		
Connectors	MC4 or equivalent (IP67)		
Hail test (max. hailstorm)	Ø 45 mm   impact velocity 23 m/s		

The specifications and average values can vary slightly. What is important is the corresponding data of the individual measurement. Specifications are subject to change without notice. Measurement tolerance: rated power +/-3%, other values +/-10%, all information in this data sheet corresponds to DIN 50380. A potential light-induced degradation of the power after commissioning is not considered here, other information can be found in the installation guidelines.

1 The specific warranty conditions are given under www.luxor-solar.com/download.htm

2 For standing installation

3 Tolerance L/W = +/- 3 mm, H = the dimensions given in the order confirmation will be decisive


4 Location on request

Luxor, your specialised company

Guidelines: 2006/95/EG-2006/95/EC,89/336/EWG-89/336/EEC,93/68/EWG-93/68/EEC



The validity of the certificates/listings for a specific country has to be examined under: www.luxor-solar.com/download.htm




A: 4 x drainage 10\*10 mm


B: 8 x ventilation aperture 3\*7 mm


C: 8 x mounting hole<sup>4</sup> d = 7 mm

D: 2 x earthing d = 2 mm

### **Electrical characteristics**







 $1000 \, W/m^2$